

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/26/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G073		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 04/23/2012	
NAME OF PROVIDER OR SUPPLIER EASTER SEALS ARC OF NORTHEAST				STREET ADDRESS, CITY, STATE, ZIP CODE 1414 INWOOD DR FORT WAYNE, IN 46815			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code Certification Survey and Environmental Preoccupancy survey for a temporary replacement home was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(J).</p> <p>Survey Date: 04/23/12</p> <p>Facility Number: 000617 Provider Number: 15G073 AIM Number: 100233770</p> <p>Surveyor: Amy Kelley, Life Safety Code Specialist</p> <p>At this Life Safety Code and Environmental Preoccupancy survey, Easter Seals ARC of Northeast Indiana was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(J), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies and with 410 IAC 9, Community Residential Facilities for Persons with Developmental Disabilities.</p> <p>This fully sprinklered facility was located in two separate four bedroom units on the first floor of a four story apartment building. The apartment building is provided with a monitored fire alarm system with interconnected hardwired smoke detectors located in each bedroom and in the hallway near the living room. The facility has a capacity of 8 and had a census of 8 at the time of this survey.</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/26/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G073		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 04/23/2012	
NAME OF PROVIDER OR SUPPLIER EASTER SEALS ARC OF NORTHEAST				STREET ADDRESS, CITY, STATE, ZIP CODE 1414 INWOOD DR FORT WAYNE, IN 46815			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>Continued From page 1</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Slow with an E-Score of 4.5.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 04/25/12.</p>			K 000			